




Williamson County Emergency Services District No. 3

Fire Lane Striping Detail

NOTES:


FIRE LANE STRIPING TO BE 6" WIDE RED PAINT WITH "FIRE LANE TOW AWAY ZONE" IN 4" TALL WHITE LETTERS. WORDING MAY NOT BE SPACED GREATER THAN 30' APART. STRIPING TO BE PAINTED ON THE FACE OF CURB WHEN PRESENT AND PAINTED FLAT ON THE PARKING SURFACE WHEN IT IS NOT.



FIRE LANE STRIPING DETAIL

not to scale

D:\Standards\Const-Stnds\Fire-Lane-Striping_Curb.dwg



Jay Engineering Company, Inc.
P.O. Box 1220
Leander, Texas 78646-1220
Tel. (512) 259-3882 Fax. (512) 259-8016

TEXAS REGISTERED ENGINEERING FIRM F-4780

FIRE LANE STRIPING DETAIL

ENGINEER	DATE	DRAWN BY	PROJECT NO.	DRAWING NO.
FRANK T. PHELAN, P.E.	04 - 25 - 19	JJD	01	1 OF 1